

Rapporto/Report No. K 2864 2020 B7

Decreto 7 Novembre 2017, n. 186
Certificazione ambientale del generatore di
calore

Tipo / Type:
SP282-02

Modello / Model:
CPS 20

Produttore / Manufacturer:
GRUPPO PIAZZETTA S.p.A.

Marchio commerciale / Trademark:
SUPERIOR

**This report may only be published and forwarded to third parties in its complete, unabridged form. The publication or dissemination of extracts, summaries, appraisals or any other adaptation and alterations, in particular for advertising purposes, is only permissible with the prior written permission of TÜV Rheinland.
Publication of page 2 is permitted.**

Decreto 7 Novembre 2017, n. 186

Certificazione ambientale del generatore di calore

Produttore / <i>Manufacturer:</i>	GRUPPO PIAZZETTA S.p.A. Via Montello, 22 31011 Asolo (TV) - Italy
Marchio commerciale / <i>Trademark:</i>	SUPERIOR
Tipo / <i>Type:</i>	SP282-02
Model / <i>Model:</i>	CPS 20
Tipologia prodotto / <i>Product type:</i>	Caldaia a pellets di legna / <i>Wood pellet boiler</i>
Norma di riferimento / <i>Reference standard:</i>	EN 303-5:2012
Ente Notificato CPR/ <i>Notified body acc. CPR</i>	NB 2456
Rapporto di Prova di riferimento / <i>Reference test report:</i>	K28642020Z1
Potenza termica nominale / <i>Nominal heat output:</i>	19,6 kW
Combustibile di prova / <i>Test fuel:</i>	Pellet di legna / <i>wood pellet</i>

Prestazioni del generatore di calore <i>Performances of the heating appliance</i>		Classi di prestazione / Performance classes			
		5 stelle	4 stelle	3 stelle	2 stelle
PP⁽¹⁾ mg/Nm³	15	10	15	20	40
COT⁽¹⁾ mg/Nm³	10	5	10	15	20
NOx⁽¹⁾ mg/Nm³	127	120	130	145	200
CO⁽¹⁾ mg/Nm³	67	25	100	250	300
η⁽¹⁾ %	91,1	92	91	90	90

⁽¹⁾ Determinato applicando il metodo di misura della UNI EN 303-5
Determined applying the measurement method of the UNI EN 303-5

Nota: tutti i valori di concentrazione calcolati al 13% di O₂ in condizioni normali (273 K, 1013 mbar, gas secco)

Note: all the concentration values are calculated at 13% of O₂ in normal conditions (273 K, 1013 mbar, dry gas)


Sulla base delle prestazioni indicate, il generatore di calore risulta in classe
Based on the declared performances, the heating appliance is in class
4 stelle / 4 stars


Cologne, 19.06.2020
432 / mc

TÜV Rheinland Energy GmbH
Test Centre for Energy Appliances
DIN EN ISO/IEC 17025:2005
accreditation: D-PL-11120-04-00

Assessor:

Report released after review:


Dipl.-Ing. M. Ciccarelli


Dipl.-Ing. A. Pomp